

ATIC Accessibility

**To support the accessible community
in making informed travel decisions
for their individual needs**

This report prepared for:

Business name:	2 Bent Rods - BEDA
Address:	51 Dart Street
Town:	Redland Bay
Contact for enquiries:	Samantha Beckmann
Contact Number:	0403713820
Contact Email:	sam@2bentrods.com.au
Website:	https://www.2bentrods.com.au
Date:	2024-03-27 12:14

ATIC Accessibility

The following pages provides travellers with information on the businesses facilities and amenities which aims to support the traveller to make an informed decision on whether the business is suitable for their individual needs.

OVERVIEW.....	3
Business Overview.....	3
Bookings	3
Emergency Management	3
Communications	3
Other Information	3
Guide Dog and Service Animals	4
GENERAL	5
Pre-arrival, arrival and reception	5
Car Park and Access amenities.....	5
External Paths.....	5
Public Toilets/Adult change facilities	5
ADVENTURE ACTIVITIES.....	6
Adventure activities	6
EVENTS.....	7
Events	7
Report Disclaimer.....	8

OVERVIEW

Business Overview

Our business caters for the following disability types:

- Deaf or low hearing
- Limited mobility
- Wheelchairs or mobility scooters
- Cognitive or people on the Autism Spectrum



Bookings

The business offers the following methods for bookings and enquiries:

- Phone
- Email
- Webportal

Emergency Management

- Emergency and evacuation procedures are explained on arrival

Communications

Other Information

- The business accepts the companion card

Guide Dog and Service Animals

The business provides the following services for services animals:

Not specified

GENERAL

Pre-arrival, arrival and reception

The business has the following in place to support guests during pre-arrival, arrival and reception

- Information and maps are available in written form

Car Park and Access amenities

The business has the following Car Park and Access amenities

- Designated disabled parking bays
- Level or ramped access from the car park to the entrance

External Paths

External paths of travel have the following amenities are in place

- Surfaces are concrete, asphalt, smooth paving or hard packed fine gravel (max aggregate size 13mm)
- Pathways are wider than 900mm

Using Council amenities only

Public Toilets/Adult change facilities

Public Toilets/Adult change facilities have the following amenities are in place

- There is an accessible toilet for public use
- The door is at least 850mm wide
- There is a minimum of 850mm beside the toilet
- Handrails are fitted
- The toilet seat is 460mm above the floor
- There is Not sure as they are council amenities at different locations mm of clear space in front of the toilet
- The toilet seat of a contrasting colour to the floor
- The toilet seat is 460mm above the floor

ADVENTURE ACTIVITIES

Adventure activities


The adventure activities have the following facilities/amenities in place

- Our adventure activities cater for people with a disability

Adventure Activity Image(s)



School sports



small bream - Megan Bock

EVENTS

Events

Events have the following facilities/amenities in place

- Accessible toilets are available at the venue
- There is good circulation space with the number of people expected to allow people with a disability to move around freely
- The event is outdoors
- Seating is at regular intervals
- Side shows, activities etc. are accessible
- Accessible car parking is available
- There are designated drop-off points

Report Disclaimer

Please note that this business report, provided as a result of the use of the diagnostic assessment, is for information purposes only.

Australian Tourism Industry Council (ATIC) cannot guarantee the accuracy of respondent's answers, or that they are fully representative of your business. Therefore, ATIC does not warrant or guarantee any particular outcome in respect of your businesses self-assessment.

This report is intended as guidance only for your business and should not be relied on for future marketing considerations. ATIC recommends that you seek your own independent advice as well as the results from the diagnostic.

Links to external web sites are inserted for convenience and do not constitute endorsement of material at those sites, or any associated organisation, product or service.

ATIC does not:

- a) Assume any legal liability for the accuracy, completeness, or usefulness of any information from this report or any links provided; or
- b) Accept responsibility for any loss associated directly or indirectly from the use of this report.